

To: Offerors
From: **Faybein M. Moy**, Contracting Officer
Date: April 25th, 2016

Subject: Answers to the Questions asked by offerors for “Install Railing for Handicap Ramp & Walkway” (SPK330-16-Q-5805) during and after site visit on April 19, 2016

1. Q) What is the exact length of the railing?

Ans) 430 ft.

2. Q) Diameter of the pipes?

Ans) -Main frame piping size 2”

-Hand Rail pipe size 1-1/2”

-Main Frame cage pipe size- 3/4”

3. Q) What is the Gauge of MS pipe?

Ans) Schedule 40.

4. Is concrete required for this project?

Ans) No.